



PRODUCT PERFORMANCE REPORT

Document ID 1495264007

Issued on May 20th, 2017

PROJECT IDENTIFICATION

- This product performance report is delivered for:

Name **Milos Sebek**
Project reference **Without project**
Project location **Serbia and Montenegro**

PRODUCT IDENTIFICATION

Certification Diploma N° **94.01.198**
Brand **FUJITSU**
Range **ASY**L**
Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
Product reference **AOYG12LMCA / ASYG12LMCA**

Important notice:

I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>

II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	61	dB(A)
Lw11 env	59	dB(A)
Cooling		
Pdesignc	3.4	kW
SEER	7.0	
SEER Class	A++	
Qce	170.0	kWh/y
EER @+35	3.5	
General		
Mounting	High Wall	
MPS	230-1-50	
Refr. Line	5.0m	m
Refrigerant	R410A	
Heating		
Pdesignh	3.5	kW
SCOP	4.0	
SCOP Class	A+	
Qhe	1225.0	kWh/y
Tbiv	-7	C
Ph @Tbiv	3.1	kW
COP @Tbiv	2.43	
TOL	-15.0	C
Ph @ TOL	2.6	kW



PRODUCT PERFORMANCE REPORT

Document ID 1495264007

Issued on May 20th, 2017

FEATURE	VALUE	UNIT
COP @TOL	1.91	
Ph @+7	4.0	kW
COP @+7	3.92	
Power input in other modes		
Poff	3.7	W
Psb	3.7	W
Pto	2.3	W
Pck	22.9	W