

PRODUCT PERFORMANCE REPORT

Document ID 1495264123

Issued on May 20th, 2017

PROJECT IDENTIFICATION

- This product performance report is delivered for:

Name **Milos Sebek**
Project reference **Without project**
Project location **Serbia and Montenegro**

PRODUCT IDENTIFICATION

Certification Diploma N° **17.02.279**
Brand **MITSUBISHI HEAVY INDUSTRIES THERMAL SYSTEMS**
Range **RANGE-AC1-MITSUBISHI HEAVY INDUSTRIES THERMAL SYST**
Product type **Comfort Air Conditioners / up to 12 kW / Air cooled / Split / Reverse cycle**
Product reference **SRC35ZMP-S/SRK35ZMP-S**

Important notice:

- I. Data featured in this report are valid at the date of issue. The scope of this product performance report does not include all certified data that can be checked at <http://www.eurovent-certification.com>
- II. This product performance report is valid only for above product features and should not be referred to as a Diploma.

FEATURE	VALUE	UNIT
Acoustic		
LwO env	60	dB(A)
Lw11 env	60	dB(A)
Cooling		
Pdesignnc	3.2	kW
SEER	6.15	
SEER Class	A++	
Qce	183.0	kWh/y
EER @+35	3.22	
General		
Mounting	W	
MPS	230-1-50	
Refr. Line	5m	m
Refrigerant	R410A	
Heating		
Pdesignnh	3.0	kW
SCOP	4.0	
SCOP Class	A+	
Qhe	1052.0	kWh/y
Tbiv	-7	C
Ph @Tbiv	2.65	kW
COP @Tbiv	2.28	



PRODUCT PERFORMANCE REPORT

Document ID 1495264123

Issued on May 20th, 2017

FEATURE	VALUE	UNIT
TOL	-15.0	C
Ph @ TOL	2.35	kW
COP @TOL	2.13	
Ph @+7	3.6	kW
COP @+7	3.62	
Power input in other modes		
Poff	6.0	W
Psb	6.0	W
Pto	25.0	W